Year	Generation		
	Targets (MU)	Actual (MU)	Actual generation as % of target
2002-03	545,552	531,607	97.4
2003-04	572,900	558,336	97.4
2004-05	586,412	587,416	100.1
2005-06	621,500	617,510	99.3
2006-07	663,000	662,523	99.9
TOTAL:	2,989,364	2,957,392	98.9

Thus, the actual energy generation in the country during the Tenth Plan Period has been 98.9% of the target.

(c) No, Sir.

(d) Does not arise in view of answer to part(c) of the reply.

(e) The National Electricity Policy envisages "Power for all by 2012" and per capita availability of power to be increased to over 1,000 units by 2011-12. The steps taken/proposed to be taken to achieve this include:

- Augmentation of generation capacity. Capacity addition to the tune of 78,500 MW is proposed for the Eleventh Plan.
- Development of Ultra Mega Power Projects of 4000 MW capacity each under tariff based competitive bidding route.
- Strengthening of inter-State and inter-regional transmission capacity for optimum utilization of available power.
- Accelerated Power Development and Reforms Programme (APDRP) for reduction of AT &C losses, etc.
- Harnessing surplus captive power into the grid.
- Promoting demand side management, energy efficiency and energy conservation measures.

Supply of coal to power plants in Rajasthan

• †854. SHRI LALIT KISHORE CHATURVEDI: Will the Minister of POWER be pleased to state:

(a) the estimated demand of coal in thermal power projects set up in Surajgarh and Kota in Rajasthan; and

(b) the quantity of coal to be arranged for these projects and from which sources to meet that demand?

†Original notice of the question was received in Hindi.

THE MINISTER OF POWER (SHRI SUSHILKUMAR SHINDE) (a) and (b) The estimated demand of coal, quantity and sources for Suratgarh and Kota Thermal Power Stations in the State of Rajasthan are as under:

(Figures in million tonnes per year)

Sl. No.	Power Stations	Demand	Source of Supply		Remarks
			Quantity	Source	
1.	Suratgarh TPS (1250 MW)	6.30	6.1 01 0.248 0.181	SECL NCL Import	Existing TPS. The quantity supplied is for the year 2006-07.
2.	Suratgarh Extn (250 MW)	1.25	1.25	SECL	Anticipated to be commissioned in 2008-09
3.	Kota TPS (1045 MW)	5.80	4.971 0.451 0.024	SECL NCL Import	Existing TPS. The quantity supplied is for the year 2006-07.
4.	Kota Extn (195 MW)	0.90	0.90	SECL	Anticipated to be commissioned in 2008-09

Quality of power supply

855. SHRI C. RAMACHANDRAIAH: Will the Minister of POWER be pleased to state:

(a) whether the State Electricity Boards and the Discoms have, in their citizen charter, an assurance to supply quality power, without voltage fluctuations and disruptions;

(b) if so, whether any supervisory mechanism is in place, to monitor those assurances;

(c) the observations the monitoring body had made during 2005-06 and 2006-07 regarding the poor power situation in Andhra Pradesh; and

(d) the measures taken to address the problem?

THE MINISTER OF POWER (SHRI SUSHILKUMAR SHINDE): (a) and (b) Under Section 57 of the Electricity Act, 2003, the concerned State Electricity Regulatory Commission (SERC), in consultation with a Distribution Company (discom) is empowered to specify standards of performance. The Act also provides for constitution of a Forum for redressal of consumers' grievances by the Discom and for an Ombudsman to be appointed by the Regulatory Commission for setting the grievances not resolved in the Forum. In addition, some Discoms have also adopted Citizens' Charter assuring certain level of service.